


Example of configuration type HTC1W-5V-DB..... T+RH+CO2 measurement with additional DS18B20 temperature sensor



- 1 humidity measured by sensor SHT31- $RH [\%] = -12,5 + 125 \cdot (VAD/VDD)$
- 2 concentration CO2 - $CO2 [ppm] = 1250 \cdot VAD$
- 3 temperature measured by sensor DS2438
- 4 temperature measured by sensor DS18B20